


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 390/2023.

Dated: 27.06.2023

It is certified that an inspection team headed by Dr. R. Narsimha CAS.(Name of Officers with designation) from CHC Kodad(Name of Department/ Office) inspected the New Vision School, Kodad(Name & Address of the school) on 27.6.23 (date of inspection) and found that the New Vision School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.The above is valid for a period of 26.06.2024Signature with Seal: 

Name

Designation

Name & Address of the Office / Department: CHC, Kodad


To

NEW VISION SCHOOL
KODAD.

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

For. Reyansh Educational Societ


Authorized Signatory
PRINCIPAL
New Vision School
KODAD (V&M)
Suryapet Dist - 508 206.

TEST REPORT

Government of Telangana

District Level Water Quality Monitoring Laboratory

(Mission Bhagiratha Department) Nalgonda

Report on Microbiological Analysis Report of Water (Drinking)

Sample Received from: Sri. D.Appa Rao, New Vision School.
Date of collection: 16/12/2023
Date of Receipt : 16/12/2023

Date of analysis: 18/12/2023
Date of report issue: 19/12/2023

S.NO	Lab Ref. No	MANDAL	NAME OF GP	LOCATION OF THE SOURCE	SOURCE TYPE	MPN Coif form Bacteria in (100 ml)	E.Coil form Bacteria in (100 ml)	REMARKS
Acceptable - Permissible Limits as per BIS 10500								
1	2397	Kodad	Kodad	New Vision School, NH65, Bypass Road, Ward No.8, Kodad (V&Mdl.), Suryapet District.	Bore Well	Shall not be detected in any 100 ml sample 0	Shall not be detected in any 100 ml sample (CFU) 0	Satisfactory

Microbiologist *[Signature]*
District Laboratory : Nalgonda

End of Report

[Signature]
19/12/2023
Chemist
WQM (District) Laboratory
Nalgonda.

For. Royansh Educational Society
[Signature]
Authorised Signatory

PRINCIPAL
New Vision School
KODAD (V&M)
Suryapet Dist - 508 206.

TEST REPORT
 Government of Telangana
 District Level Water Quality Monitoring Laboratory
 (Mission Bhaglratha Department) Nalgonda
 Report on Chemical Analysis of Water (Drinking)
 (General Physico-Chemical Parameters)

Sample Received From : Sri. D.Appa Rao, New Vision School.
 Date of Collection: 16/12/2023
 Date of Receipt : 16/12/2023

Date of analysis: 18/12/2023
 Date of report issue: 19/12/2023

Lab Ref.No	Mandal	GP/Hab	Sample location	Source	pH	TURBIDITY		Electrical conductivity $\mu\text{S/cm}$	Total Dissolved Solids mg/lit	Total Alkalinity as CaCO_3 mg/lit	Total Hardness as CaCO_3 mg/lit	Chloride as Cl mg/lit	Fluoride as F mg/lit	Nitrate as NO_3 mg/lit	Sulphate as SO_4 mg/lit	Iron as Fe mg/lit	Remarks
						NTU	(1 - 5 NTU)										
BIS: 10500-2012 Acceptable - Permissible limits																	
					6.5 - 8.5			-	500-2000	200-600	200-600	250-1000	1.0-1.5	45	200-400	0.3 - 1.0	
2396	Kodad	Kodad	New Vision School, NH65, Bypass Road, Ward No.8, Kodad (V&Mdl.), Suryapet District.	Bore Well	7.36	0.6		1210	786	340	364	163	0.92	12.1	62.8	0.10	Satisfactory

Red
 19/12/2023
 Chemist
 WQM (District) Laboratory
 Nalgonda.

Red
 PRINCIPAL
 New Vision School
 - KODAD (V&M)
 Suryapet Dist - 508-206.

Red
 For. Royanish Educational Society
 Authorised Signatory